

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
sand	0	13
coarse sand & gravel w/ rocks	13	33
12-20 slot sand	33	57
15-40 slot sand w/ rocks	57	65
12-20 slot sand	65	98
12-40 slot sand w/ 1-2" rocks	98	123
10-12 slot sand	123	133
12-20 slot sand w/ 1-2" rocks	133	158
12-40 slot sand w/ 1" rocks	158	174

Total Depth **174**

Casing: 16" STEEL A 53 WELDED from 2' to 144'
 16" SCREEN from 144' to 174'

Screen: 30' of 16" diameter 60 slot

Grout: BENT SLURRY from 0 to 117
 BENT CHIPS from 117 to 127

Water from sand at 127' to 174'

Static level 83' below casing top which is 2' above GL

Pumping level 120' when pumping at 350 gpm for 5 hr(s)

Permanent pump installed at 120' on 8/15/2023, with a capacity of 350 gpm

Remarks: Driller's Estimated Well Yield 350 gpm

Owner Address: 10000 Marquis Dr Hennepin, IL

Address of well: none assigned Hennepin, IL Hennepin IL

Location source: Global Positioning System verified

Permit Date: March 7, 2023

Permit #: 155-003-2023

COMPANY Albrecht Well Drilling Inc

FARM Marquis Land Holdings

DATE DRILLED April 21, 2023

NO. 6005

ELEVATION '

COUNTY NO. 20932

LOCATION

LATITUDE 41.261111

LONGITUDE -89.311944

COUNTY Putnam

API# 1215520932 00

11-32N-2W