

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	15
reddish shale	15	20
brown sandstone	20	24
white sandstone	24	47
light brown sandstone	47	102
reddish sandstone	102	138
light brown sandstone	138	154
white sandstone	154	178
brown sandstone	178	179

Total Depth **179**

Casing: 6" PVC from -1' to 151'

Size hole below casing: 6"

Water from white sandstone at 154' to 178'

Pumping level 179' when pumping at 19 gpm for 1 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Owner Address: Rural Route Steeleville, IL

Location source: Location from permit

Permit Date: October 24, 1978 **Permit #:** 81144

COMPANY Hepp, Frank

FARM Crawford, Robert P.

DATE DRILLED October 24, 1978 **NO.**

ELEVATION ' **COUNTY NO.** 23288

LOCATION

LATITUDE 37.917548 **LONGITUDE** -89.671534

COUNTY Randolph **API#** 1215723288 00 **17-7S-5W**