

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
surface	0	0
no record	0	18
gray till	18	40
soft brown sandstone	40	90
brown sandstone	90	102
light brown sandstone	102	150

Total Depth **150**

Casing: 6" PVC from -2' to 103'

Grout: NEAT CEMENT from 0 to 103

Water from light brn sandstone at 103' to 150'

Static level 60' below casing top which is 2' above GL

Pumping level 100' when pumping at 30 gpm for 1 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Owner Address: 4914 Mueller Ln Steeleville, IL

Address of well: same as above

Location source: Location from permit

Permit Date: July 21, 2008

Permit #: 157-09-003

COMPANY Hepp, Frank D. Jr.

FARM Mueller, Paul

DATE DRILLED August 8, 2008

NO. 1

ELEVATION '

COUNTY NO. 26585

LOCATION

LATITUDE 37.993478

LONGITUDE -89.671349

COUNTY Randolph

API# 1215726585 00

20-6S-5W