

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay brown	0	25
clay gray	25	30
clay brown, soft	30	36
clay brown, soft, little sandy	36	49
clay brown, firm 1" rocks	49	51
clay brown, small gravel, sand	51	56
sand brown, fine	56	72
clay gray, soft	72	76

Total Depth

76

Casing: 6" PVC CERTALOC from -1' to 67'

6" PVC CERTALOC from 72' to 76'

6" SCREEN from 67' to 72'

Screen: 5' of 6" diameter 0.03 slot

Grout: BENTONITE from 0 to 19

Water from sand at 56' to 72'

Static level 45' below casing top which is 1' above GL

Remarks: Drillers Estimated Well Yield 20 gpm

Owner Address: 7890 Griggs Rd Red Bud, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: September 28, 2018

Permit #: 157-009-2018

COMPANY Beckett, Donald

FARM Ordmesher, James

DATE DRILLED October 17, 2018

NO.

ELEVATION

COUNTY NO. 26764

LOCATION

LATITUDE 38.171667

LONGITUDE -89.903333

COUNTY Randolph

API# 1215726764 00

20-4S-7W