

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	3
clay yellow	0	16
gray clay	16	21
brown sand	21	25
gravel dirty	25	28
gray clay	28	43
hard gray clay	43	63
shale hard sandy	63	68
sand nice	68	87
tight clean	87	87
shale gray	87	124
sandstone shaley	124	140

Total Depth **140**

Grout: BENSEAL from 0 to 68

Static level 15' below casing top which is ' above GL

Pumping level 70' when pumping at 1 gpm for 24 hr(s)

Permanent pump installed at 70' on 6/26/2017, with a capacity of 7 gpm

Remarks: Driller's Estimated Well Yield .75 gpm

Owner Address: 8053 E. Hurricane Lane Claremont, IL

Address of well: same as above

Location source: Location from permit

Permit Date: June 6, 2017

Permit #: 159-005-17

COMPANY Sloan, Thomas F.

FARM Mashburn, Bill

DATE DRILLED June 26, 2017

NO.

ELEVATION '

COUNTY NO. 26516

LOCATION

LATITUDE 38.907832

LONGITUDE -87.924128

COUNTY Richland

API# 1215926516 00

1-5N-14W