

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow clay	0	12
sandrock & shale	12	21
gray & brown lime	21	69
gray & brown lime w/shale streaks	69	166
Niagara	166	202

Total Depth

202

Casing: 6" T&C STEEL SCH 40 from 0' to 169'

Grout: CUTTINGS from 0 to 169

Size hole below casing: 6"

Water from Niagara at 166' to 202'

Static level 66' below casing top which is 1' above GL

Pumping level 100' when pumping at 12 gpm for 1 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Owner Address: 8325 R.R. #150 Coal Valley, IL

Location source: Location from permit

Permit Date: January 30, 1990

Permit #: 016769

COMPANY Adolphson, Robert M. Jr.

FARM Garrity, Florence

DATE DRILLED August 30, 1990

NO.

ELEVATION 0'

COUNTY NO. 22217

LOCATION

LATITUDE 41.436301

LONGITUDE -90.478899

COUNTY Rock Island

API# 1216122217 00

27-17N-1W