

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	40
gray shale	40	120
broken limestone	120	215

Total Depth **215**

Casing: 6" PVC from 0' to 140'

4.5" PVC SLOT from 131' to 215'

Screen: 84' of 4.5" diameter slot

Grout: BENSEAL from 0 to 140

Water from broken limestone at 140' to 215'

Static level 80' below casing top which is 2' above GL

Pumping level 140' when pumping at 15 gpm for 4 hr(s)

Permanent pump installed at 140' on 4/10/2010, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 15 gpm

Owner Address: 4321 230th St Port Byron, IL

Address of well: 4210 230th St. Port Byron, IL Port Byron IL

Location source: Location from permit

Permit Date: February 18, 2010

Permit #: 161-WW02-10

COMPANY Timmerman, Tom

FARM Wainwright, Ken

DATE DRILLED March 2, 2010

NO.

ELEVATION '

COUNTY NO. 24140

LOCATION

LATITUDE 41.562607

LONGITUDE -90.293880

COUNTY Rock Island

API# 1216124140 00

8-18N-2E