

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	50
shale	50	77
coal	77	80
shale	80	268
limestone	268	420
shale	420	423
limestone/patchy shale	423	495

Total Depth **495**

Casing: 6" SDR21 PVC from -2' to 198'
 6" SDR17 PVC from 198' to 318'
 4.5" SDR17 SOL-PVC from 315' to 415'
 4.5" SCH40 SLO-PVC from 415' to 495'

Grout: BENSEAL from 0 to 318

Water from limestone at 415' to 495'

Static level 255' below casing top which is ' above GL

Pumping level 300' when pumping at 30 gpm for hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 14414 175th St. W. Taylor Ridge, IL

Address of well: 14329 175th St. W. Taylor Ridge, IL 61284 Taylor Ridge IL

Location source: Global Positioning System verified

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

Related File - Unknown File Type

Permit Date: April 26, 2013

Permit #: 161-WW-009-2013

COMPANY Kelso, James

FARM Stegmiller, Bob

DATE DRILLED May 7, 2013

NO.

ELEVATION '

COUNTY NO. 24386

LOCATION

LATITUDE 41.377433

LONGITUDE -90.811475

COUNTY Rock Island

API# 1216124386 00

14-16N-4W