

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow firm clay	0	52
gray firm clay	52	167
gray firm shale	167	218
tan hard limestone	218	325
gray hard limestone	325	455

Total Depth **455**

Casing: 6" PVC SDR 21 from -1' to 200'
 6.9" PVC SDR 17 from 200' to 260'
 4.5" PVC SDR 17 from 255' to 295'
 4.5" PVC SCH 40 from 295' to 455'

Grout: BENSEAL from 0 to 260
 NEAT CEMENT from 255 to 295

Water from limestone at 355' to 455'

Static level 283' below casing top which is 2' above GL

Pumping level 340' when pumping at 30 gpm for 1 hr(s)

Permanent pump installed at 320' on 3/13/2018, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 13011 28th Street W. Milan, IL

Address of well: 13120 28th St. W. Milan, IL 61264 Milan IL

Location source: Global Positioning System verified

Permit Date: December 14, 2017 **Permit #:** 161-29-17

COMPANY Gingerich, Emery Duane

FARM Nordick, Gary & Chris

DATE DRILLED December 20, 2017 **NO.**

ELEVATION ' **COUNTY NO.** 24580

LOCATION

LATITUDE 41.386727 **LONGITUDE** -90.607702

COUNTY Rock Island **API#** 1216124580 00 **9-16N-2W**