

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
black dirt	0	3
tan clay	3	18
gray clay & sand	18	28
gray clay	28	47
gray clay & coal	47	67
dark gray shale	67	183
light gray shale	183	190
white limestone w/ streams of shale	190	200
white limestone	200	295
fractured white limestone	295	518
sandstone	518	535
white & gray limestone	535	562
gray shale	562	585

Total Depth

585

Casing: 12" STEEL THREADED from -2' to 290'

Grout: NEAT CEMENT from 0 to 290

Water from limestone at 200' to 562'

Static level 293' below casing top which is 2' above GL

Pumping level 283' when pumping at 295 gpm for 24 hr(s)

Permanent pump installed at 400' on , with a capacity of 150 gpm

Remarks: Driller's Estimated Well Yield 205 gpm

Owner Address: 121 11th St Silvis, IL

Address of well: Lot 600 Hospital Rd Silvis, IL Silvis IL

Location source: Location from the driller

Permit Date: February 3, 2021

Permit #: 161-WW01-2021

COMPANY Gingerich, Klint

FARM Village of Silvis

DATE DRILLED March 1, 2021

NO.

ELEVATION '

COUNTY NO. 24756

LOCATION

LATITUDE 41.492131

LONGITUDE -90.419258

COUNTY Rock Island

API# 1216124756 00

6-17N-1E