

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	64
brown broken shaley limestone	64	130
brown limestone	130	180
light gray limestone	180	300

Total Depth **300**

Casing: 6" ASTM F 480 PVC from -1' to 100'
5" ASTM F 480 PVC from 100' to 140'

Grout: BENTONITE from 0 to 100

Water from rock at 180' to 300'

Static level 43' below casing top which is 1' above GL

Pumping level 60' when pumping at 25 gpm for 1 hr(s)

Permanent pump installed at 80' on 1/17/2023, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 25 gpm

Owner Address: 27101 94th Ave N Port Byron, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: December 9, 2022 **Permit #:** 161-WW41-2022

COMPANY White, Matt

FARM Wollenburg, Robert & Jessica

DATE DRILLED December 13, 2022 **NO.**

ELEVATION ' **COUNTY NO.** 24838

LOCATION

LATITUDE 41.613750 **LONGITUDE** -90.246943

COUNTY Rock Island **API#** 1216124838 00 **23-19N-2E**