

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow firm clay	0	13
tan hard limestone	13	120
light gray hard limestone	120	215

Total Depth **215**

Casing: 6" PVC SDR 21 from -1' to 120'
5" PVC SCH 40 from 115' to 215'

Grout: BENSEAL from 0 to 120

Water from limestone at 150' to 215'

Static level 85' below casing top which is 2' above GL

Pumping level 140' when pumping at 20 gpm for 1 hr(s)

Permanent pump installed at 146' on 10/10/2023, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 20 gpm

Owner Address: 7704 24th St Milan, IL

Address of well: same as above

Location source: Location from the driller

Permit Date: October 13, 2023

Permit #: 161-WW28-23

COMPANY Gelement, Val

FARM Puckett, Anthony

DATE DRILLED October 17, 2023

NO.

ELEVATION '

COUNTY NO. 24865

LOCATION

LATITUDE 41.445116

LONGITUDE -90.435704

COUNTY Rock Island

API# 1216124865 00

24-17N-1W