

Water Well	Top	Bottom
interlayered clay&silt w/very fine sand	0	31
silty fine sand	31	55
fine to coarse sand trace gravel	55	69

Total Depth

69

Casing: 12" PVC from 0' to 10'

12" SCREEN from 10' to 69'

Screen: 59' of 12" diameter 0.035 slot

Grout: BENTONITE from 0 to 10

WASHED GRADED SAND from 10 to 69

Static level 10' below casing top which is 2' above GL

Pumping level 55' when pumping at 500 gpm for 24 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 500 gpm

Address of well: 1000 South 22nd Street

Add'l loc info: Subdivision: Cahokia

Location source: Global Positioning System verified

Permit Date: September 27, 2016

Permit #: 529-01-16

COMPANY	Skouby, Charles A.
----------------	--------------------

FARM Alton & Southern RR

DATE DRILLED October 11, 2016

NO. 3

ELEVATION 414' GL

COUNTY NO. 31348

LOCATION

LATITUDE 38.598725

LONGITUDE -90.150667

COUNTY St. Clair

API# 1216331348 00

25-2N-10W