

Water Well	Top	Bottom
interlayered clay & silt very f sand	0	31
silty fine sand	31	65
fine to coarse sand trace gravel	65	70

Total Depth

70

Casing: 12" PVC from 0' to 20'

12" SCREEN from 20' to 70'

Screen: 50' of 12" diameter 0.035 slot

Grout: BENTONITE from 0 to 20

WASTHED GRADED SAND from 20 to 70

Static level 10' below casing top which is 2' above GL

Pumping level 55' when pumping at 500 gpm for 24 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 500 gpm

Address of well: 1000 South 22nd Street

Add'l loc info: Subdivision: Cahokia

Location source: Global Positioning System verified

Permit Date: September 27, 2016

Permit #: 529-01-16

COMPANY	Skouby, Charles A.
----------------	--------------------

FARM Alton & Southern RR

DATE DRILLED October 12, 2016

NO. 6

ELEVATION 414' GL

COUNTY NO. 31351

LOCATION

LATITUDE 38.598669

LONGITUDE -90.150233

COUNTY St. Clair

API# 1216331351 00

25-2N-10W