

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
black silty clay	0	2
brown silty clay	2	7
light brown & gray sandy silty clay	7	18
brown fine sand/some med/coarse sand	18	35

Total Depth **35**

Casing: 6" PVC SDR 21 from -1' to 12'

30" FIBERGLASS BELL JT from 12' to 35'

Screen: 23' of 30" diameter 0.05 slot

Grout: BENT CHIPS from 10 to 11

Water from fine brown sand at 18' to 35'

Static level 17' below casing top which is 1' above GL

Remarks: Driller's Estimated Well Yield 14 gpm

Owner Address: 19444 Mech Illiop Rd Illiopolis, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: November 2, 2023

Permit #: 167-033-2023

COMPANY Harry T Waters

FARM Ford, Tyler

DATE DRILLED March 25, 2024

NO. 1

ELEVATION '

COUNTY NO. 27016

LOCATION

LATITUDE 39.814878

LONGITUDE -89.283719

COUNTY Sangamon

API# 1216727016 00

26-16N-2W