

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
sand & gravel	0	94

Total Depth **94**

Casing: 18" STEEL .375 WALL from -2' to 54'

Screen: 40' of 18" diameter 0.0599999986588955 slot

Grout: 6 BAG MIX from 0 to 20

Size hole below casing: 42"

Water from sand & gravel at 13' to 94'

Static level 15' below casing top which is 2' above GL

Pumping level 34' when pumping at 2000 gpm for 4 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Sample set # 64490 0' - 90' Received: 6/15/1984

Owner Address: Municipal Building Jacksonville, IL

Location source: Location from permit

Permit Date: June 10, 1982

Permit #: 103748

COMPANY Miller J P Co

FARM Jacksonville, City of

DATE DRILLED June 21, 1982

NO. 1

ELEVATION 0'

COUNTY NO. 20265

LOCATION 2098'S line, 960'W line of NE

LATITUDE 39.755877

LONGITUDE -90.608119

COUNTY Scott

API# 1217120265 00

12-15N-14W