

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
tan clay	0	18
tan sand	18	19
gray clay	19	25
gray sand	25	26
gray clay	26	51

Total Depth

51

Casing: 5" PVC from -1' to 10'
 36" TILE from 10' to 51'

Grout: BENSEAL from 8 to 10
 PEA GRAVEL from 10 to 51

Water from sand at 25' to 26'

Static level 14' below casing top which is 1' above GL

Pumping level 30' when pumping at 1 gpm for 1 hr(s)

Permanent pump installed at 50' on 10/24/2002, with a capacity of 10 gpm

Remarks: driller's est well yield 1 gpm

Owner Address: R.R. 1 Box 76 Shelbyville, IL

Address of well: same as above

Location source: Location from permit

Permit Date: September 10, 2002

Permit #:

COMPANY Courson, Roger

FARM Roley, Dick

DATE DRILLED October 17, 2002

NO. 1

ELEVATION 0'

COUNTY NO. 23999

LOCATION

LATITUDE 39.329700

LONGITUDE -88.776894

COUNTY Shelby

API# 1217323999 00

8-10N-4E