

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
soil & yellow clay	0	8
dirty sand & gravel	8	17
dirty sandstone	17	83
shale	83	87

Total Depth **87**

Casing: 5" PVC GLUED from -2' to 30'

Grout: QUICK GROUT from 0 to 26

Water from dirty sandstone at 30' to 83'

Static level 7' below casing top which is 2' above GL

Pumping level 30' when pumping at 3 gpm for 24 hr(s)

Permanent pump installed at 30' on 6/13/2022, with a capacity of 36 gpm

Remarks: Driller's Estimated Well Yield 3 gpm

Owner Address: 815 N 2400 E Rd Strasburg, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: June 2, 2022

Permit #: 173-002-2022

COMPANY Baker, J. Curtis

FARM Buhrmester, Branden

DATE DRILLED June 6, 2022

NO.

ELEVATION '

COUNTY NO. 24532

LOCATION

LATITUDE 39.333000

LONGITUDE -88.693000

COUNTY Shelby

API# 1217324532 00

6-10N-5E