

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	16
soft fractured limestone	16	38
limestone	38	76
dolomite	76	248
Glenwood	248	255
sandstone	255	280

Total Depth **280**

Casing: 6" STEEL from -1' to 84'

Grout: BENTONITE from 0 to 84

Water from sandstone at 255' to 280'

Static level 84' below casing top which is 1' above GL

Pumping level 120' when pumping at 25 gpm for 1 hr(s)

Permanent pump installed at 140' on 9/21/2006, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 55 gpm

Owner Address: 4154 Farwell Bridge Rd. German Valley, IL

Address of well: 9164 E. Kelly Rd. Ridott, IL Ridott IL

Location source: Location from permit

Permit Date: September 15, 2006 **Permit #:** 177-33-06

COMPANY Edward M. Deppe

FARM Cornelius, Rhett

DATE DRILLED September 19, 2006 **NO.**

ELEVATION 880' **COUNTY NO.** 23034

LOCATION

LATITUDE 42.246716 **LONGITUDE** -89.429691

COUNTY Stephenson **API#** 1217723034 00 **14-26N-9E**