

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
fill	0	4
brown clay	4	23
yellow limestone	23	80
gray shale	80	94
St. Pete sandstone	94	205

Total Depth **205**

Casing: 5" A53B from -1' to 108'

Grout: BENSEAL from 0 to 108

Water from sandstone at 110' to 205'

Static level 60' below casing top which is 1' above GL

Pumping level 80' when pumping at 10 gpm for 6 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 60 gpm

Owner Address: 6138 N. Farwell Bridge Rd. Rock City, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: July 17, 2018

Permit #: 177-13-18

COMPANY Schuur, Bill

FARM Gall, Kenn

DATE DRILLED July 26, 2018

NO.

ELEVATION '

COUNTY NO. 23398

LOCATION

LATITUDE 42.391778

LONGITUDE -88.429167

COUNTY Stephenson

API# 1217723398 00

26-28N-9E