

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
black topsoil	0	2
yellow clay	2	15
blue clay	15	29
yellow limestone	29	41
grey limestone	41	146
sandstone	146	180

Total Depth **180**

Casing: 6" ASTMA 53B from 2' to 78'

Grout: NEAT CEMENT from 74 to 79
BENTONITE from 0 to 74

Water from sandstone at 146' to 180'

Static level 85' below casing top which is 2' above GL

Pumping level 140' when pumping at 20 gpm for 2 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Drillers Estimated Well Yield 40 gpm

Owner Address: 10886 N Hulbert Rd McConnell, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: October 22, 2019

Permit #: 177-15-2019

COMPANY Thompson, John J.

FARM Lobdell, Chad

DATE DRILLED October 25, 2019

NO.

ELEVATION '

COUNTY NO. 23403

LOCATION

LATITUDE 42.456944

LONGITUDE -89.732222

COUNTY Stephenson

API# 1217723403 00

6-28N-7E