

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil & brown clay	0	12
broken limestone	12	14
galena limestone	14	73
trenton mc gregor limestone	73	188
glenwood	188	198
sandstone	198	230

Total Depth **230**

Casing: 6" WELDED STEEL from 0' to 98'

Grout: NEAT CEMENT from 2 to 99

Water from limestone/sandstone at 122' to 230'

Static level 122' below casing top which is 2' above GL

Pumping level 140' when pumping at 20 gpm for 1 hr(s)

Permanent pump installed at 170' on 6/28/2022, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 20 gpm

Owner Address: 7168 E Rock Grove Rd Rock City, IL

Address of well: same as above

Location source: Location from the driller

Permit Date: April 18, 2022

Permit #: 177-06-2022

COMPANY Niffenegger Well & Pump

FARM Stambaugh, Roger & Christy

DATE DRILLED June 17, 2022

NO.

ELEVATION '

COUNTY NO. 23414

LOCATION

LATITUDE 42.462183

LONGITUDE -89.476822

COUNTY Stephenson

API# 1217723414 00

33-29N-9E