

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil & clay	0	10
broken limestone	10	18
galena limestone	18	62
gray limestone	62	78
trenton mc gregor	78	128
sandstone	128	150

Total Depth **150**

Casing: 6" STD STEEL from 0' to 99'

Water from sandstone at 128' to 150'

Static level 22' below casing top which is 2' above GL

Pumping level 35' when pumping at 30 gpm for 1 hr(s)

Permanent pump installed at 50' on 8/24/2022, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 4523 E River Rd Ridott, IL

Address of well: 4520 E River Rd Ridott, IL Ridott IL

Location source: Location from the driller

Permit Date: August 15, 2022

Permit #: 177-15-2022

COMPANY Niffenegger Well & Pump

FARM Meier, Kim

DATE DRILLED August 18, 2022

NO.

ELEVATION '

COUNTY NO. 23421

LOCATION

LATITUDE 42.313716

LONGITUDE -89.520031

COUNTY Stephenson

API# 1217723421 00

25-27N-8E