

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
fine sand	0	15
fine sand - medium gravel	15	35
fine sand	35	40
fine-medium sand	40	45
fine sand	45	90
fine sand - medium gravel	90	120

Total Depth **120**

Casing: 10" PVC from 0' to 100'
10" SCREEN from 100' to 120'

Screen: 20' of 10" diameter 0.05 slot

Grout: BENTONITE from 0 to 25
FA4 from 25 to 120

Static level 49' below casing top which is 2' above GL

Owner Address: 343 N. Church Street Green Valley, IL

Address of well: Woodrow Road

Location source: Global Positioning System verified

Permit Date: March 21, 2012

Permit #: 179-15487-2012

COMPANY Dowell, S.L.

FARM Coriell, Luke

DATE DRILLED April 10, 2012

NO.

ELEVATION '

COUNTY NO. 25456

LOCATION

LATITUDE 40.421750

LONGITUDE -89.659389

COUNTY Tazewell

API# 1217925456 00

22-23N-5W