

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	3
mixed sandy clay	3	9
brown sand fine	9	35
brown sand & gravel	35	50
brown sand fine	50	65
brown sand medium/fine	65	117

Total Depth **117**

Casing: 16" SDR 26 PVC from -1' to 117'

16" SCREEN from 97' to 117'

Screen: 20' of 16" diameter 0.05 slot

Grout: CONCRETE from 0 to 14

BUCKSHOT BLEND from 14 to 117

Water from sand at 35' to 117'

Static level 36' below casing top which is 1' above GL

Remarks: Driller's Estimated Well Yield 1000 gpm

Owner Address: 5183 Chapel Rd. Green Valley, IL

Address of well: 14067 Woodrow Rd. Green Valley, IL 61534 Green Valley IL

Location source: Global Positioning System verified

Permit Date: December 21, 2015

Permit #: 179-15936-16

COMPANY Erwin, James

FARM Ruth, Vernon L.

DATE DRILLED February 25, 2016

NO. 1

ELEVATION '

COUNTY NO. 25706

LOCATION

LATITUDE 40.418028

LONGITUDE -89.657750

COUNTY Tazewell

API# 1217925706 00

27-23N-5W