

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay yellow	0	15
clay gray	15	95
sand	95	119
sand coarse	119	140
sand & gravel	140	193

Total Depth **193**

Casing: 16" PVC GLUE from -2' to 171'

16" SCREEN/SS LAG from 171' to 193'

Screen: 22' of 16" diameter 50 slot

Grout: BENSEAL T100 from 0 to 50

Water from sand & gravel at 171' to 193'

Static level 104' below casing top which is 2' above GL

Pumping level 160' when pumping at 1000 gpm for 6 hr(s)

Permanent pump installed at 168' on 4/10/2020, with a capacity of 1000 gpm

Remarks: Driller's Estimated Well Yield 1000 gpm

Owner Address: 22428 Townline Rd Tremont, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: October 8, 2019

Permit #: 179-16188-2019

COMPANY Sauder, Steven E.

FARM Greiner Enterprises

DATE DRILLED January 24, 2020

NO.

ELEVATION '

COUNTY NO. 25913

LOCATION

LATITUDE 40.484981

LONGITUDE -89.506672

COUNTY Tazewell

API# 1217925913 00

36-24N-4W