

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay yellow	0	12
clay gray	12	147
sand fine	147	167
sand coarse	167	179
sand & gravel	179	247

Total Depth **247**

Casing: 16" PVC GLUE from -2' to 225'

16" SCREEN/SS from 225' to 247'

Screen: 22' of 16" diameter 50 slot

Grout: BENSEAL from 0 to 110

Water from sand & gravel at 225' to 247'

Static level 155' below casing top which is 2' above GL

Pumping level 206' when pumping at 600 gpm for 3 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 600 gpm

Owner Address: Delavan Rd Delavan, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: September 10, 2020 **Permit #:** 179-16237-2020

COMPANY Sauder, Steven E.

FARM JB Property

DATE DRILLED October 20, 2020 **NO.**

ELEVATION ' **COUNTY NO.** 25926

LOCATION

LATITUDE 40.423250 **LONGITUDE** -89.549133

COUNTY Tazewell **API#** 1217925926 00 **21-23N-4W**