

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	3
sand	3	26
sand & gravel	26	75

Total Depth

75

Casing: 5" PVC from 0' to 70'

5" SCREEN from 70' to 75'

Screen: 5' of 5" diameter 20 slot

Grout: BENTONITE from 0 to 50

Water from sand & gravel at 75' to 70'

Static level 43' below casing top which is 1' above GL

Pumping level 46' when pumping at 10 gpm for 2 hr(s)

Permanent pump installed at 60' on 3/27/2022, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 20 gpm

Owner Address: 7326 Spruce St Manito, IL

Address of well: same as above

Location source: Location from the driller

Permit Date: February 25, 2022

Permit #: 179-16326-2022

COMPANY Cole, Steve

FARM Cissell, Nathan

DATE DRILLED March 26, 2022

NO.

ELEVATION

COUNTY NO. 25995

LOCATION

LATITUDE 40.510540

LONGITUDE -89.790713

COUNTY Tazewell

API# 1217925995 00

21-24N-6W