

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown sandy clay	0	14
brown sand	14	16
gray rocky clay	16	50

Total Depth

50

Casing: 36" CONCRETE from 14' to 50'

6" PVC SDR 21 SOLVENT from -1' to 14'

Grout: BENTONITE from 13 to 14

Water from sand at 14' to 16'

Static level 7' below casing top which is 1' above GL

Pumping level ' when pumping at 700 gpm for hr(s)

Remarks: Driller's Estimated Well Yield 15 gpm

Owner Address: 5754 N 1270 East Rd Georgetown, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: December 12, 2022

Permit #: 183-2683-2022

COMPANY Harper, David

FARM Lafoe, Jim

DATE DRILLED December 15, 2022

NO.

ELEVATION '

COUNTY NO. 27226

LOCATION

LATITUDE 39.947281

LONGITUDE -87.698249

COUNTY Vermilion

API# 1218327226 00

10-17N-12W