

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow clay	0	20
shale & streaks of sandstone	20	185
limestone	185	325

Total Depth **325**

Casing: 6" PVC from 0' to 62'

4.5" PVC SLOTTED from 45' to 185'

Grout: BENSEAL from 0 to 62

Water from limestone at 185' to 325'

Static level 95' below casing top which is 2' above GL

Pumping level 315' when pumping at 9 gpm for 2 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 8.5 gpm

Owner Address: 180 W. Maple Roseville, IL

Address of well: 395 80th Ave. Roseville, IL Roseville IL

Location source: Global Positioning System verified

Permit Date: December 20, 2011 **Permit #:** 187-20-2011

COMPANY Kremer, Jack Lee

FARM Ross, Mervin

DATE DRILLED January 16, 2012 **NO.**

ELEVATION 730' **COUNTY NO.** 22117

LOCATION

LATITUDE 40.746726 **LONGITUDE** -90.715458

COUNTY Warren **API#** 1218722117 00 **27-9N-3W**