

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	10
sandstone	10	28
sandrock	28	60
hard lime	60	64
sandrock	64	87

Total Depth

87

Casing: 5" PVC from 0' to 87'

5" SCREEN from 37' to 87'

Screen: 50' of 5" diameter 0.12 slot

Grout: CEMENT from 8 to 35

BENTONITE from 3 to 8

SAND from 35 to 36

PEA GRAVEL from 36 to 37

Water from sandrock at 28' to 87'

Static level 8' below casing top which is 2' above GL

Pumping level 75' when pumping at 30 gpm for 1 hr(s)

Permanent pump installed at 60' on 9/8/2019, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 30+ gpm

Owner Address: 2138 CR 2300 E. Clay City, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: April 23, 2019

Permit #: 191-02-19

COMPANY Jones, Gerald K.

FARM Krupp, Adam

DATE DRILLED September 8, 2019

NO.

ELEVATION '

COUNTY NO. 33221

LOCATION

LATITUDE 38.561444

LONGITUDE -88.275500

COUNTY Wayne

API# 1219133221 00

36-2N-8E