

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	25
sandy clay	25	35
fine sand	35	50
sand & gravel	50	70

Total Depth **70**

Casing: 16" PVC from 0' to 50'

16" PVC SCREEN from 50' to 70'

Screen: 20' of 16" diameter 0.5 slot

Grout: BENTONITE from to

Water from sand & gravel at 50' to 70'

Static level 15' below casing top which is 1' above GL

Pumping level 40' when pumping at 800 gpm for 1 hr(s)

Permanent pump installed at 50' on 5/3/2004, with a capacity of 800 gpm

Owner Address: 598 Co. Rd. 1725 East Carmi, IL

Location source: Platbook verified

Verified by: JMG on 10/12/2012

Permit Date: April 1, 2004

Permit #: 193-04-04

COMPANY Warth, William

FARM Baumgart, Ed

DATE DRILLED April 13, 2004

NO.

ELEVATION 360' GL

COUNTY NO. 32293

LOCATION 2293'N line, 400'E line of

LATITUDE 37.972242

LONGITUDE -88.133736

COUNTY White

API# 1219332293 00

29-6S-10E