

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	10
fine brown sand	10	12
coarse brown sand/med gravel	12	18
coarse gray sand/medium gravel	18	35
coarse gray sand/pea gravel	35	45

Total Depth

45

Casing: 16" SDR 26 PVC from 0' to 25'

16" SCREEN from 25' to 45'

Screen: 20' of 16" diameter 0.035 slot

Grout: BENTONITE from 20 to 22

#4 ALLENDALE S&G from 22 to 45

Water from sand & gravel at 12' to 45'

Static level 10' below casing top which is 1' above GL

Pumping level 12' when pumping at 300 gpm for 1 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 1000 gpm

Owner Address: 7833 E 400 Mount Carmel, IL

Address of well: CR 2250E Crossville, IL 62827 Crossville IL

Location source: Global Positioning System verified

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

Related File - Unknown File Type

Permit Date: July 15, 2014

Permit #: 193-13-14

COMPANY Gobel, Joseph Louis

FARM Hocking, Todd

DATE DRILLED July 16, 2014

NO.

ELEVATION '

COUNTY NO. 33365

LOCATION

LATITUDE 38.182500

LONGITUDE -87.966111

COUNTY White

API# 1219333365 00

15-4S-11E