

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	15
shale	15	120
sandy shale	120	135
sandstone	135	205

Total Depth **205**

Casing: 6" WELDED PVC from 0' to 36'
5" WELDED PVC from 36' to 205'

Grout: EZ SEAL from 0 to 35

Water from sandstone at 155' to 205'

Static level 141' below casing top which is 1' above GL

Pumping level 120' when pumping at 10 gpm for 1 hr(s)

Permanent pump installed at 180' on 3/30/2021, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 15 gpm

Owner Address: 316 Co Rd 900 N Norris City, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: April 22, 2021

Permit #: 193-03-2021

COMPANY Scates, Thomas L.

FARM Scroggins, David

DATE DRILLED March 28, 2021

NO.

ELEVATION 472' GL

COUNTY NO. 34325

LOCATION

LATITUDE 38.010689

LONGITUDE -88.315767

COUNTY White

API# 1219334325 00

10-6S-8E