

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay top soil	0	14
brown fine sand	14	20
gray sand	20	45
large gravel	45	60
fine gray sand	60	70
large gravel	70	76

Total Depth

76

Casing: 16" PVC SDR 26 from 0' to 36'

Screen: 40' of 16" diameter 0.05 slot

Grout: TOP SOIL from 0 to 2

3/8 HOLE PLUG from 3 to 10

Water from gray sad at 37' to 76'

Static level 19' below casing top which is 4' above GL

Remarks: Driller's Estimated Well Yield 800 gpm

Owner Address: 472 CR 1375 E New Haven, IL

Location source: Global Positioning System verified

Permit Date: May 13, 2020

Permit #: 193-02-2020

COMPANY Scates, Thomas L.

FARM Ackerman, Frances

DATE DRILLED May 26, 2020

NO.

ELEVATION 364' GL

COUNTY NO. 34436

LOCATION

LATITUDE 37.939098

LONGITUDE -88.094286

COUNTY White

API# 1219334436 00

3-7S-10E