

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
sandy clay	0	32
gray clay	32	65
gravel	65	95

Total Depth

95

Casing: 6" PVC from 0' to 87'

Screen: 4' of 6" diameter 20 slot

Size hole below casing: 6"

Water from sand & gravel at 87' to 91'

Static level 10' below casing top which is 1' above GL

Pumping level 30' when pumping at 30 gpm for 2 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Owner Address: R.R. #2 9931 Polo Rd. Rock Falls, IL

Location source: Location from permit

Permit Date: August 4, 1981

Permit #: 100780

COMPANY Forder, James

FARM Rosengren, Don

DATE DRILLED August 5, 1981

NO.

ELEVATION 0'

COUNTY NO. 21274

LOCATION

LATITUDE 41.721157

LONGITUDE -89.652303

COUNTY Whiteside

API# 1219521274 00

14-20N-7E