

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	2
fine sand	2	20
medium sand	20	32
medium gravel	32	57
fine sand at	57	57

Total Depth

57

Casing: 10" PVC from 0' to 37'

10" SS SCREEN from 37' to 57'

Screen: 20' of 10" diameter 0.05 slot

Grout: BENTONITE from 0 to 20

Static level 21' below casing top which is 0' above GL

Pumping level 38' when pumping at 650 gpm for 0 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Owner Address: % Merle Gaulrapp 9179 Tampico Rd. Rock Falls, IL

Location source: Location from permit

Permit Date: November 4, 1993

Permit #:

COMPANY Klassen, Genevieve "Sue"

FARM Gaulrapp Turkey Farm

DATE DRILLED December 13, 1993

NO.

ELEVATION 0'

COUNTY NO. 21905

LOCATION

LATITUDE 41.718996

LONGITUDE -89.772869

COUNTY Whiteside

API# 1219521905 00

14-20N-6E