

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	18
yellow lime	18	70
light gray lime	70	190
shale	190	230
shale rock	230	340
tan limestone	340	505

Total Depth **505**

Casing: 6" ASTM A53B from 0' to 84'

Grout: BENTONITE from 0 to 84

Water from tan limestone at 340' to 505'

Static level 178' below casing top which is 1' above GL

Pumping level 505' when pumping at 22 gpm for 2 hr(s)

Permanent pump installed at 420' on 12/1/2000, with a capacity of 12 gpm

Remarks: driller's est. well yield 22 gpm

Owner Address: 439 Martin Rd. Rock Falls, IL

Address of well: 15846 Golf Hills Rd. Sterling, IL Sterling IL

Add'l loc info: Lot: 8 & 9 Subdivision: Golf Hills

Location source: Location from permit

Permit Date: August 24, 2000

Permit #:

COMPANY Dresden, Edward L.

FARM Wise, Alva

DATE DRILLED December 1, 2000

NO. 1

ELEVATION 0'

COUNTY NO. 22756

LOCATION

LATITUDE 41.812893

LONGITUDE -89.803805

COUNTY Whiteside

API# 1219522756 00

15-21N-6E