

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow clay	0	32
gray clay	32	70
dark gray lime	70	103
tan lime	103	155
light gray	155	190
gray lime	190	205

Total Depth **205**

Casing: 6" ASTM A53B from 0' to 84'

Grout: BENTONITE from 0 to 84

Water from gray lime at 155' to 205'

Static level 31' below casing top which is 2' above GL

Pumping level 205' when pumping at 150 gpm for 1 hr(s)

Permanent pump installed at 80' on , with a capacity of 0 gpm

Remarks: driller's est. well yield 150+ gpm

Owner Address: 26972 Pilgrim Rd. Sterling, IL

Address of well: same as above

Location source: Location from permit

Permit Date: October 26, 2000

Permit #:

COMPANY Dresden, Edward L.

FARM Linscheid, Clayton

DATE DRILLED December 1, 2000

NO. 2

ELEVATION 0'

COUNTY NO. 22757

LOCATION

LATITUDE 41.903019

LONGITUDE -89.726733

COUNTY Whiteside

API# 1219522757 00

7-22N-7E