

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	22
yellow lime	22	35
gray lime	35	49
shale	49	80
shale rock	80	205

Total Depth **205**

Casing: 6" ASTM A53B from 0' to 105'

Grout: BENTONITE from 0 to 105

Water from shale rock at 80' to 205'

Static level 54' below casing top which is 1' above GL

Pumping level 205' when pumping at 30 gpm for 2 hr(s)

Permanent pump installed at 140' on , with a capacity of 0 gpm

Remarks: driller's est. well yield 30 gpm

Owner Address: 1010 6th Ave. Sterling, IL

Address of well: 1001 E. 35th St. Sterling, IL Sterling IL

Add'l loc info: Lot: 10 Subdivision: Windsor Crest

Location source: Location from permit

Permit Date: August 21, 2000

Permit #:

COMPANY Dresden, Edward L.

FARM Feather, Bill

DATE DRILLED December 1, 2000

NO. 1

ELEVATION 0'

COUNTY NO. 22759

LOCATION

LATITUDE 41.820393

LONGITUDE -89.684518

COUNTY Whiteside

API# 1219522759 00

10-21N-7E