

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow sand	0	64
gravel	64	90
gray sand	90	103

Total Depth **103**

Casing: 6" PVC SDR 21 from -1' to 80'

4.5" PVC SCH 40 from 76' to 98'

4.5" PVC SCREEN from 98' to 103'

Screen: 5' of 4.5" diameter 0.02 slot

Grout: BENSEAL from 0 to 80

NATURAL from 98 to 103

Water from sand at 98' to 103'

Static level 28' below casing top which is 1' above GL

Pumping level 60' when pumping at 15 gpm for 2 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 18 gpm

Owner Address: 4965 Holly Road Fulton, IL

Address of well: same as above

Location source: Location from permit

Permit Date: February 23, 2007 **Permit #:** 195-07-008-2007

COMPANY Joseph Allen

FARM Petersen, Rick

DATE DRILLED February 27, 2007 **NO.**

ELEVATION ' **COUNTY NO.** 23766

LOCATION

LATITUDE 41.830000 **LONGITUDE** -90.151111

COUNTY Whiteside **API#** 1219523766 00 **9-21N-3E**