

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
coarse red sand	0	10
yellow/brown limestone	10	240
Sulurian	240	302

Total Depth **302**

Casing: 8" PVC from -1' to 60'

Grout: BENTONITE from 0 to 60

Water from rock at 240' to 302'

Static level 6' below casing top which is 1' above GL

Pumping level 220' when pumping at 350 gpm for 1 hr(s)

Permanent pump installed at 144' on 7/20/2015, with a capacity of 425 gpm

Remarks: Driller's Estimated Well Yield 350

Owner Address: 19170 Acker Rd. Fulton, IL

Address of well: Off Sand Rd. Erie, IL Erie IL

Location source: Location from permit

Permit Date: March 26, 2015

Permit #: 195-15-009-15

COMPANY Latta, Kirk Stephen

FARM Bush, Douglas

DATE DRILLED May 18, 2015

NO.

ELEVATION '

COUNTY NO. 24464

LOCATION

LATITUDE 41.623561

LONGITUDE -90.141158

COUNTY Whiteside

API# 1219524464 00

22-19N-3E