

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	30
shale	30	70
limestone white/hard	70	132
shale	132	203
limestone shale/gray	203	330
limestone gray	330	565
guttenberg	565	570

Total Depth

570

Casing: 6" a53b steel t/c from -1' to 339'

Grout: QUICK GROUT from 339 to 0

Water from limestone at 339' to 570'

Static level 238' below casing top which is 1' above GL

Pumping level 320' when pumping at 18 gpm for 5 hr(s)

Permanent pump installed at 320' on 1/5/2024, with a capacity of 10 gpm

Remarks:

Owner Address: 23757 Hazel Rd Sterling, IL

Address of well: 23757 Hazel Rd Sterling IL

Add'l loc info: Lot: Subdivision:

Location source: Global Positioning System verified

Permit Date: December 18, 2023 Permit #: 195-008-24

COMPANY Roop, Randy/Jonas Martin Drlg.

FARM Smith, John & Rhonda

DATE DRILLED January 3, 2024

NO.

ELEVATION

COUNTY NO. 24951

LOCATION

LATITUDE 41.815306

LONGITUDE -89.790444

COUNTY Whiteside

API# 1219524951 00

15-21N-6E