

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	15
yellow limestone	15	112
gray shale w/ limestone ledges	112	305
tan limestone	305	430

Total Depth **430**

Casing: 6" pvc casing sdr 21 from -1' to 80'
5" liner PVC sch 40 from 30' to 330'
5" perf liner pvc sch 4 from 330' to 430'

Grout: BENTONITE from 0 to 80

Water from rock at 305' to 430'

Static level 109' below casing top which is 1' above GL

Pumping level 220' when pumping at 10 gpm for 1 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks:

Owner Address: 3805 E 20th St Sterling, IL

Address of well: 3805 E 20th St Sterling IL

Add'l loc info: Lot: 46 Subdivision: Candlelight Manor

Location source: Global Positioning System verified

Permit Date: January 23, 2024

Permit #: 195-018-24

COMPANY Harvey, Lucius

FARM Billings, Joe & Dawn

DATE DRILLED February 6, 2024

NO.

ELEVATION '

COUNTY NO. 24956

LOCATION

LATITUDE 41.806028

LONGITUDE -89.650778

COUNTY Whiteside

API# 1219524956 00

14-21N-7E