

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	42
limestone	42	220

Total Depth **220**

Casing: 5" BLACK STEEL from 0' to 42'

Grout: CUTTINGS from 0 to 42

Size hole below casing: 5"

Water from limestone at ' to '

Static level 120' below casing top which is 1' above GL

Pumping level 140' when pumping at 10 gpm for 4 hr(s)

Permanent pump installed at 140' on , with a capacity of 10 gpm

Remarks: owner instructed to take sample

Owner Address: 4310 McClintock Rd. Joliet, IL

Location source: Location from permit

Verified by: VJA on 6/25/2014

Permit Date: May 31, 1984

Permit #: 112630

COMPANY Rob, Peter

FARM Lou Von Homes

DATE DRILLED June 6, 1984

NO.

ELEVATION '

COUNTY NO. 32198

LOCATION

LATITUDE 41.581086

LONGITUDE -88.141600

COUNTY Will

API# 1219732198 00

19-36N-10E