

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	2
limestone	2	180

Total Depth **180**

Casing: 5" PVC SDR 17 from 0' to 40'

Grout: BENTONITE from 0 to 40

Water from limestone at 140' to 180'

Static level 60' below casing top which is 1' above GL

Pumping level 140' when pumping at 12 gpm for 0 hr(s)

Permanent pump installed at 140' on 12/20/2004, with a capacity of 12 gpm

Remarks: driller's est well yield 15 gpm

Owner Address: 214 Peale St. Joliet, IL

Address of well: 1714 Broadway Crest Hill, IL Crest Hill IL

Add'l loc info: Lot: 22 & 23

Location source: Aerial Photograph verified

Verified by: VJA on 7/3/2014

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

Related File - Unknown File Type

Permit Date: December 17, 2004 **Permit #:** 197-0386-04

COMPANY Bisping, Calvin

FARM Ahmod, Kdabil

DATE DRILLED December 19, 2004 **NO.**

ELEVATION 0' **COUNTY NO.** 41533

LOCATION

LATITUDE 41.555449 **LONGITUDE** -88.087989

COUNTY Will **API#** 1219741533 00 **33-36N-10E**