

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	47
limestone	47	165

Total Depth **165**

Casing: 5" STEEL from -1' to 52'

Grout: BENTONITE from 5 to 52

Water from limestone at 52' to 165'

Static level 60' below casing top which is ' above GL

Pumping level 100' when pumping at gpm for hr(s)

Permanent pump installed at 120' on 12/18/2006, with a capacity of 12 gpm

Remarks: Driller's Estimated Well Yield 25 gpm

Owner Address: 308 Siesta Dr. New Lenox, IL

Address of well: 546 Fox Street Joliet, IL Joliet IL

Add'l loc info: Lot: 275 Subdivision: Ridgewood

Location source: Aerial Photograph verified

Verified by: VJA on 10/2/2014

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

Related File - Unknown File Type

Permit Date: October 18, 2006

Permit #: 197-0297-06

COMPANY Matherly, Hubert

FARM Murphy, Dan

DATE DRILLED November 15, 2006

NO.

ELEVATION 778'

COUNTY NO. 42085

LOCATION

LATITUDE 41.536728

LONGITUDE -88.034144

COUNTY Will

API# 1219742085 00

12-35N-10E