

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	55
gravel	55	65
limestone	65	180

Total Depth **180**

Casing: 5" PVC from -1' to 70'

Grout: BENTONITE from -5 to 70

Water from limestone at 70' to 180'

Static level 40' below casing top which is 1' above GL

Pumping level 70' when pumping at 20 gpm for 1 hr(s)

Permanent pump installed at 140' on 1/8/2009, with a capacity of 20 gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 10439 Santa Cruz Ln Orland Park, IL

Address of well: 13148 Maple Rd.

Location source: Global Positioning System verified

Verified by: VJA on 4/30/2013

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

Related File - Unknown File Type

Permit Date: November 14, 2008 **Permit #:** 197-0152-08

COMPANY Fykes, Charles N.

FARM Pekau, Keith

DATE DRILLED December 12, 2009 **NO.**

ELEVATION 718' **COUNTY NO.** 42637

LOCATION

LATITUDE 41.550433 **LONGITUDE** -87.939017

COUNTY Will **API#** 1219742637 00 **2-35N-11E**