

# ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

| Water Well            | Top | Bottom |
|-----------------------|-----|--------|
| brown clay            | 0   | 15     |
| gray clay with gravel | 15  | 75     |
| gravel                | 75  | 130    |
| rock                  | 130 | 200    |

**Total Depth** 200

Casing: 6" PVC from 0' to 136'

Grout: ENVORPLUS from 0 to 135

Water from rock at 150' to 200'

Static level 90' below casing top which is 1' above GL

Pumping level 100' when pumping at 20 gpm for 1 hr(s)

Permanent pump installed at 140' on 7/23/2014, with a capacity of 20 gpm

Remarks: Driller's Estimated Well Yield 25 gpm

Owner Address: 7235 W. 83 St. Bridge View, IL

Address of well: 13961 S. Cokes Rd. Homer Glen, IL Homer Glen IL

Add'l loc info: Lot: 5 Subdivision: Carli Acres

Location source: Field verified

Verified by: VJA on 3/31/2015

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

Related File - Unknown File Type

**Permit Date:**

**Permit #:**

**COMPANY** Comar Drilling Co., Inc.

**FARM** Bukowski, Jozef & Lottie

**DATE DRILLED** July 21, 2014

**NO.**

**ELEVATION** '

**COUNTY NO.** 43649

**LOCATION**

**LATITUDE** 41.633010

**LONGITUDE** -88.006960

**COUNTY** Will

**API#** 1219743649 00

**5-36N-11E**