

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	4
gravel	4	22
gray & white lime	22	220
gray lime hard shale	220	300
limestone	300	460

Total Depth

460

Casing: 6.25" PVC from -1' to 43'

Grout: CEMENT from 0 to 43

Water from limestone at 260' to 460'

Static level 300' below casing top which is 1' above GL

Pumping level 440' when pumping at 5 gpm for hr(s)

Permanent pump installed at 440' on 8/6/2014, with a capacity of 5 gpm

Remarks: Driller's Estimated Well Yield 6 gpm

Owner Address: 618 Elmwood Joliet, IL

Address of well: same as above

Location source: Field verified

Verified by: VJA on 3/31/2015

[Imaged Log viewing help: New users please read this.](#)

[GET FILE](#)

Related File - Unknown File Type

Permit Date: July 30, 2014

Permit #: 197-0041-14

COMPANY Comar Drilling Co., Inc.

FARM Robinson, Larry

DATE DRILLED August 5, 2014

NO.

ELEVATION '

COUNTY NO. 43651

LOCATION

LATITUDE 41.515260

LONGITUDE -88.063980

COUNTY Will

API# 1219743651 00

15-35N-10E